

Submittal Data Sheet

Project
Information

Project Number	Approval

Features

- Meets NFPA 99 standard
- 3 piece in-line easy to service
- Dual gauge/purge ports
- Full port 1/4 turn ball valve
- Cleaned for Oxygen service
- Adjustable packing with blow-out proof stem
- Working pressure rating of 600 psi WOG (29 in/Hg vacuum)
- Complies with Federal Standard WW-V35B, Type II, Composition: BZ, Style 1, requirements
- Available in sizes ½" − 3"
- Brass 1/8 NPT Female gauge/purge ports
- Type K copper extensions
- Optional locking handles available
- 100% tested

Specifications

All valves shall be Tri-Tech Medical 51 series and must be installed and tested in strict accordance with NFPA 99 standards and or any local codes before use.

The valves shall be bronze, ball-type, with Teflon (TFE) seats and seals. Valves shall be rated at working pressure of 600 psi (29 in/Hg vacuum) and shall be operated by a lever-type handle requiring only a quarter turn from fully open position to a fully closed position. Optional locking handles are available.

All valves shall be equipped with type K copper tubing extensions with two brass 1/8 NPT female gauge/purge ports (one on each side of the valve), to facilitate installation. Gauge/purge ports shall be shipped with a 1/8 NPT plug. Valves shall be 3 piece in-line repairable type. Valves shall incorporate an adjustable packing and blow-out proof stem. Only full port valves having flow rates comparable to equivalent size of pipe shall be used.



Adhesive backed caution labels shall be acquired separately and field installed. The labels shall state: CAUTION – (gas name) VALVE, DO NOT CLOSE EXCEPT IN EMERGENCY and/or any other required labeling per NFPA 99. Labels shall be color coded for the appropriate gas service and include a section for stating the area being serviced by the valve.

Each valve assembly shall be supplied cleaned for oxygen service in accordance with the current Compressed Gas Association (CGA) Pamphlet G-4.1, ends capped and sealed in a polyethylene bag to prevent contamination prior to installation.

NFPA – National Fire Protection Association Pamphlet 99 "Health Care Facilities"

CGA – Compressed Gas Association Pamphlet G-4.1 "Cleaning Equipment for Oxygen Service"




BALL VALVES w/ EXTENSIONS & TWO GAUGE PORTS

Dimensions

Note: Gauge port supplied w/ 1/8" NPT Plug



Gauge Port Design



Ordering Information

Six Bolt used on 2 ½", 3" & 4" Valves

	Ball Valve Assemblies – without labels (order gas labels separately)													
Size Valve	Standard Handle Part#	w/ Locking Handle Part#	A	Dimensions A B C D E F G H J K L							M			
1/2"	51-02	51-02LH	6.56	11.82	2.62	1.69	3.35	21.00	2.38	6.37	7.87	1.31	0.93	-
3/4**	51-03	51-03LH	6.78	11.28	2.93	1.89	4.33	21.00	2.69	6.06	8.25	1.43	1.43	-
1'	51-04	51-04LH	6.86	10.70	3.44	2.05	4.33	21.00	2.88	5.87	8.58	1.62	1.62	-
1 1/4"	51-05	51-05LH	6.77	10.27	3.96	2.56	5.12	21.00	3.25	5.50	8.75	2.00	2.00	-
1 1/2"	51-06	51-06LH	6.65	9.92	4.43	2.72	5.12	21.00	3.38	5.37	8.87	2.25	2.25	-
2"	51-07	51-07LH	8.09	7.35	5.55	3.15	6.30	21.00	3.75	5.00	10.87	2.81	2.81	-
2 1/2"	51-08	51-08LH	12.64	12.64	6.73	4.29	9.06	32.00	4.25	4.25	16.00	2.50	4.33	5.00
3"	51-09	51-09LH	12.22	12.22	7.56	4.61	9.06	32.00	4.50	4.50	16.00	2.75	4.73	5.00
4"	51-10	51-10LH	11.10	11.10	9.80	7.00	12.00	32.00	8.00	8.00	16.00	3.75	6.50	7.50

Gauges & Labels

Pressu	re Gauge	Gas ID Labels Cards – sold in Pkgs of (10)					
Pressure gauges 1-1/2" diame	ter 1/8" NPT center back mount	Gas	Color	Part #			
Scale	Part Number	N2O	USA-ISO	ZV104-7I			
0-100 psi	14-1008	CO ₂	USA-ISO	ZV108-71			
0-300 psi	14-1009	N2	USA-ISO	ZV112-71			
0-30 in Hg	14-1010	AIR	USA	ZV116-71			
		AIR	ISO	ZV116-81			
		VAC	USA	ZV122-71			
		VAC	ISO	ZV122-8I			
		O2	USA	ZV124-71			
		O2	ISO	ZV124-8I			
		WAGD (EVAC)	USA-ISO	ZV132-7F			